

June 14, 2022  
Patriot Beverages, LLC WWTP  
MA0004936-1

Ms. Nam Nguyen  
U.S. EPA, Water Enforcement  
OES4-SMR  
5 Post Office Square, Suite 100  
Boston, MA 02109-3912

Dear Ms. Nguyen:

Please find attached the Monthly Operation and Maintenance Report for May 2022.

The final effluent total phosphorous result for May averaged 0.96lbs/day with a maximum of 2.0lbs. We have installed a new chemical feed pump for the phosphorous removal coagulant. We have also purchased a HACH DR3900 and have started taking daily final effluent samples to monitor the effectiveness of the phosphorous removal. The results are improving and we are testing and making adjustments as quickly as possible.

The WWTP is receiving off-site wastewater, daily, Monday through Saturday from the CPF facility in Ayer, Ma.

If you have any questions, please contact William Barton at (978) 339-5905 or e-mail at [wbarton@patriotbev.com](mailto:wbarton@patriotbev.com).

Sincerely,



James Drapeau  
Patriot Beverages WWTP

Attachment: 001-A Discharge Monitoring Report for May 2022 submitted by NetDMR  
001-T Discharge Monitoring Report for May 2022 submitted by NetDMR  
MA DEP Monthly Operations and Maintenance Report for May 2022 submitted by NetDMR  
Off-Site Wastewater received spreadsheet for May 2022 submitted by NetDMR